

C-101

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZI/408

Dated:- 08/07/2024

To,

The Manager  
M/S Shivlok Palace Guest House,  
4648-4650, Shora Kothi,  
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Shivlok Palace Guest House located at 4648-4650, Shora Kothi, Pahar Ganj, New Delhi.**

Sir,

This has reference to on line ID No. 2024061509427 dated 15/06/24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 28/06/24 in the presence of Mr. Yogesh and following shortcomings were observed: -

1. CO type detectors found nonfunctional.
2. PA system found non functional.
3. Stand by power supply not provided.
4. Pump not in auto mode provisions.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:

Addl. Commissioner of Police( lic), Ist floor, Defence Colony Police Station, New Delhi