

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/School/2024/ 422

Dated: 10/07/2024

To,

The Principal,
Sushila Devi Public School,
B-68, Yadav Nagar, Sameypur,
Delhi 110042.

Sub: Issue of FSC in r/o Sushila Deevi Public School, B-68, Yadav Nagar, Sameypur, Delhi 110042.

Sir,

Kindly reference to online e-mail dated 05.06.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 02.07.2024, in presence of **Sh. Satya Pal Singh (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace fire pump found 450 lpm on first floor but not functional.
2. The required exit signage are not provided
3. Hose reel provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

