



75
Azadi Ka
Amrit Mahotsav

CGI

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/ 275

Dated: 05/07/2024

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Fun & Food Village, Polo Amusement Park Ltd at Old Gurgaon Road, Kapashera, New Delhi-110037

Sir,

Please refer to your office letter No. 336 – 39/Joint CP/Lic. (Amst.) dated 06/06/2024, received through outdoor diary No. 2657 dated 07/06/2024. In this connection, it is to inform you that the said premise was visited by the officers concerned of this department on dated 27/06/2024 to verify status of the fire safety arrangements provided therein. Sh. Santokh Singh Chawla (owner) was present at the time of inspection. During the inspection, the shortcomings observed are as below.

1. First-aid hose reel near kitchen found removed.
2. The fire pipe line was under repair.
3. The exit signage found removed at some places.

Keeping in view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements/certificate shall be at the risk and liability of the owner/occupier. The licensing/statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, Municipal Corporation of Delhi, Najafgarh Zone near Dhansa Bus Stand, Najafgarh, New Delhi-110043
2. Sh. Santokh Singh Chawla, Director of Polo Amusement Park, Fun & Food Village, Old Gurgaon Road, Kapashera, New Delhi-110037