

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2024 405

Dated: 08/07/2024

To,

Sh. Jai Mohan Vats (Chairman)
Happy Child Public School,
Palam Extension, Sector-7 Dwarka,
New Delhi-110075.

Subject: Issuance of Fire Safety Certificate in r/o Happy Child Public School, Located at Palam Extension, Sector-7 Dwarka, New Delhi-110075.

Sir,

Please refer to your letter no. HCPS/399/2024 dated 05/06/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by officer concerned of this department on 01/07/2024 in the presence of Sh. Sh. Jai Mohan Vats (Chairman) from fire safety point of view.

During course of inspection the following shortcomings are observed:

1. The Width of staircases is provided 1.35m & 1.5m against required 02 staircases of 1.5m width.
2. The width of class room Doors is less than 1 m clear width.
3. Exit Signage's not provided at some places.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage. You are requested to comply the abovementioned shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(Atul Garg)
Director,
Delhi Fire Service
23/7/24

Copy to:

1. The Directorate of Education Old Secretariat Delhi – 110054