

330

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 416

Dated: 09/07/2024

To,

The Manager,
Harry Model School, L-92.
Mohan Garden, Uttam Nagar, New Delhi-110059.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Harry Model School, L-92, Mohan Garden, Uttam Nagar, New Delhi-110059.

Sir,

Please refer to your letter No. HMS/2024-25 dated 04.06.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 04.07.2024 to verify the fire safety arrangements in accordance with the rules. At the time of inspection. Pawan Partap Singh (Manager) was present and it was observed that the school building was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2019/SZ/873 dated 22.04.2019 for block-A (ground floor only) & block-B (ground & first floor only) but now each block comprised of ground plus two upper floors respectively and both blocks are interconnected each other and have following shortcomings: -

1. Two staircases having width of 1.35 & 0.80 m found provided against requirement of atleast one staircase with width of 1.50 m should be provided.
2. First aid hose reel found not provided
3. Terrace fire pump capacity of 450 LPM should be provided.
4. Overhead water storage capacity of 10,000 ltrs should be provided.
5. Exit signage's found not provided.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.