

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2024/ 404

DATED: 08/07/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

**Subject: - Renewal of Fire safety Certificate in r/o M/s Hotel Prince International
Located at 1st, 2nd & 3rd floors Plot No.14A/24, Channa Market, Karol Bagh, New Delhi
- 110005.**

Sir,

Please refer to online application No. 2024061209250, dated 12/06/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 03/07/2024 in the presence of Sh. Kabir Singh from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Hose reel hose found nonfunctional.
2. MOEFA & PA system found nonfunctional.
3. Automatic Sprinkler system in basement found nonfunctional.
4. Terrace pump of capacity 450 lpm found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(Arun Garg)
Director,
Delhi Fire Service.

Copy to:-

1. The Manager, M/s Hotel Prince International Located at 1st, 2nd & 3rd floors Plot No.14A/24, Channa Market, Karol Bagh, New Delhi - 110005.