

CS

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

Dated: 10/07/2024

No. F.6/DFS/MS/WZ/GH/2024/ 410

To,

Mr. Jagdish Sharma,
House No.21, Block-F, Pocket-14,
Sector-15, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o M/s Hotel SSENSSE (Sharma Hospitality LLP), Plot no.28, Pocket.5-A, Sector-25, Rohini, Delhi-110085.

Sir,

This is reference to online application no.2024032903778 dated 10.06.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **01.07.2024**, in presence of **Mr. Gorav Sharma** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire check door not provide in staircases.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)

DIRECTOR

Ph; 011-23414000

Copy To:-

MHA Portal Id- 2024032903778 dated 10.06.2024

