



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

e/s  
7/5  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2024/284

Dated: 09/07/2024

To,

Mr. Sameer Singh (Owner),  
IBIZA A Unit of Laferia Hospitality Pvt. Ltd.  
Property No. A – 2 Third floor,  
Preet Vihar, Delhi – 110092.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s IBIZA A Unit of Laferia Hospitality Pvt. Ltd. located at Property No. A – 2 Third floor, Preet Vihar, Delhi – 110092.**

Sir,

This has a reference to your MHA Portal application No. 2024062509925 dated 26/06/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 02/07/2024 in the presence of Mr. Sameer Singh (Owner) and observed that building comprised of Basement, Stilt (Parking), Upper ground plus three floors only. (Restaurant on third floor only).

**Following shortcomings were observed during time of inspection:**

1. Fire check doors not provided.
2. First-Aid-Hose Reels provided but not functional.
3. Internal Hydrants provided but not functional.
4. Pumping arrangements of one electric pump of 1620 LPM, one jockey pump of 180 LPM and one diesel pump of 1620 LPM fire pump not provided.
5. Fire Underground water tank of capacity 1,00,000 liters not provided.
6. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c (u) DELHI FIRE SERVICE

**Copy to: -**

1. Mr. Sameer Singh, M/s IBIZA A Unit of Laferia Hospitality Pvt. Ltd. located at Property No. A – 2 Third floor, Preet Vihar, Delhi – 110092.
2. The Joint Commissioner of police (Lic), 1<sup>st</sup> Floor, P. S. Defence Colony, New Delhi-110024. w.e.f.-MHA portal ID – 2024062509925 dated 26/06/2024.