



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5-38
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2024/ 4/5

Dated: 09/07/2024

To,

The Principal,
MCD Nigam Pratibha Vidhyalaya
Vishwakarma Nagar, Delhi - 110095.

Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Nigam Pratibha Vidhyalaya located at Vishwakarma Nagar, Delhi – 110095.

Sir,

This has a reference to your email dated 04/06/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 29/06/2024 in the presence of Mr. Virender Pal Singh (HOS) and observed that building comprised of two separate block (Ground & Ground + 1).

Following shortcomings were observed during time of inspection:

1. All Fire Extinguishers found empty.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, MCD Nigam Pratibha Vidhyalaya located at Vishwakarma Nagar, Delhi – 110095.