



No. F6/DFS/MS/School/NDZ/2024/ 4/11

Dated: 09/07/2024

To,

Mr. Lokesh Kumar (Principal),  
MCD Primary School  
GT Road, Delhi – 110032..

**Subject: - Regarding grant of Fire Safety Certificate in r/o MCD Primary School located at GT Road, Delhi – 110032.**

Sir,

This has a reference to your Outdoor Diary No. 2706 dated 10/06/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 29/06/2024 in the presence of Mr. Lokesh Kumar (Principal), and observed that building comprised of ground plus two upper floors only.

**Following shortcomings were observed during time of inspection:**

1. All fire extinguishers found empty.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Overhead tank of capacity 10,000 liters not provided.
5. Exit signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to:-**

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.