

61

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2024/409

Dated:- 12.10.2024

To

The Manager  
M/S Noble International Guest House,  
133-134, Krishna Gali, Ghee Mandi,  
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o Noble International Guest House at 133-134, Krishna Gali, Ghee Mandi, Pahar Ganj, New Delhi

Sir,

This has reference to on line ID No. 2024060708971 dated 13/06/24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 27/06/24 in the presence of Manager and following shortcomings were observed: -

1. Smoke management is not provided as per gazette notification dated 27/05/19.
2. CO- detector found nonfunctional.

Hence, The case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully

(Atul Garg)

DIRECTOR

Delhi Fire Service

Copy to:

Addl. Commissioner of Police ( Lic), Ist floor, Defence Colony Police Station, New Delhi.