

C-22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/ 406
To

Dated: 08/07.../2024

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Platinum Hotels and Restaurants LLP
located at Khasra No 384, Mahipal Extension, New Delhi 110037.

Sir,

This has reference with **MHA Portal ID 2024040704400 dated 08/06/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.07.2024 in the presence of Mr. Dhananjay Singh and observed that the guest house running at Ground plus two upper floors with 85 G/Rooms to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke management system provided but found non-functional in the basement.
2. MOEFA not working.
3. Automatic Sprinkler system not provided of partition of officer area.
4. Fire fighting pumps are not on auto mode.
5. Exit signage found removed at some places.

The same observations has already been issued and communicated earlier by this department vide letter of even no 207 dated 09/05/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

[Handwritten signature]