



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/07
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/BNQT/NDZ/2024/ 87

Dated: 10/07/2024

To,

Mr. Arun Maini (Owner),
S.K. Kumar Banquet Hall
A Unit of S. K Ceremonies Pvt. Ltd
Plot No. 12 Ghazipur Auto Mobile Centre,
Ghazipur, Delhi - 110096.

Sub: - Regarding grant of Fire Safety Certificate in r/o M/s S. K. Kumar Banquet Hall (A Unit of S. K Ceremonies Pvt. Ltd) located at Plot No. 12 Ghazipur Auto Mobile Centre, Ghazipur, Delhi - 110096.

Sir,

This has a reference to your MHA Portal application No. 2024061109204 dated 11/06/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 02/07/2024 in the presence of Mr. Arun Maini (Owner) and observed that building comprised of Basement, ground plus two upper floors but banquet hall is running on Ground floor only.

Following shortcomings were observed during time of inspection:

1. Fire check doors not provided..
2. First -aid hose reel not functionable.
3. Internal hydrants not functionable.
4. Pump ground level and terrace level provided but not functionable.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. Mr. Satish Kapoor, S. K. Kumar Banquet Hall (A Unit of S. K Ceremonies Pvt. Ltd) located at Plot No. 12 Ghazipur Auto Mobile Centre, Ghazipur, Delhi - 110096..
2. The Joint Commissioner of police (Lic), 1st Floor, P. S. Defence Colony, New Delhi-110024.
w.e.f.- MHA Portal application No. 2024061109204 dated 11/06/2024.