

c/6°

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/392

Dated: 04/07/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Sonic Inn Guest House** situated at **3916, Gali Jagat Wali, Urdu Bazar, Jama Masjid, Delhi - 110006.**

Sir,

This has reference to online application I.D. no. 2024061509433 dated 15.06.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned from this department on 28.06.2024 in the presence of Mohd. Noor Islam (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Hose reel hose provided but not functional.
2. CO detectors with panel and alarm system provided but not functional.
3. Fire pump not in auto start mode.
4. Exit signages are not adequately provided.
5. Occupancy above third floor is not permitted as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 011-23414000
o/c
17

Copy to:-

The Licensee,

Sonic Inn Guest House at 3916, Gali Jagat Wali, Urdu Bazar, Jama Masjid, Delhi - 110006.