

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2024/SZ/271

Dated: 04/07/2024

To

The Addl. Commissioner of Police,  
Lic Branch 1<sup>st</sup> Floor PS Defence Colony,  
New Delhi- 110049

Sub: Regarding issuance of FSC in r/o M/s Uncle By Miss Pinto (Unit of Hungry N Thirsty Foods Pvt Ltd) Plot No 24, 1<sup>st</sup> & 2<sup>nd</sup> floor, Community Centre, Vasant Vihar, Delhi 110057

Sir,

This has reference to your **MHA Portal ID 2024060408711** dated **04/06/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 19.06.2024 in the presence of Mr. Virender Singh to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The existing building has provision of only one staircase where as another one fire escape staircase is also to be required from ground to upper floors.
2. Overhead tank capacity 5000 ltrs provided against the required of 20,000 ltrs.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully



(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

slu ms