

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI -110001**

No. F.6/DFS/MS/2024/SZ/ 399
To

Dated: 13/07/2024

Mr. Inderjeet Singh (AGM),
IFCI Limited, IFCI Tower,
61, Nehru Place, New Delhi-110019

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s IFCI Tower located Plot No 61,
Nehru Place, New Delhi 110019

Sir,

This is in reference to your letter no IFCI/Security/FSC/IFCI Tower/202-240651011 dated 21/06/2024 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection on 04/07/2024 in the presence of Mr. Inderjeet Singh (AGM) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Fire check door found damage need to be repairing or replacement.
2. First Aid hose reel provided but found non functional.
3. Automatic sprinkler system provided but found nonfunctional.
4. Fire fighting pumps not on auto mode.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE