

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/Cinema/NDZ/2024/ 4 D I

Dated: 5/07/2024

To,

Mr. Vikas Tyagi (Manager), Moon Shine Entertainment Limited for (Audi – 04, Audi no. 05 & Audi no. 06, (Chand Cinema) located at Trilok Puri, Delhi - 110091.

Subject: - Regarding grant of Fire Safety Certificate in r/o Moon Shine Entertainment Limited for (Audi - 04, Audi no. 05 & Audi no. 06, (Chand Cinema) located at Trilok Puri, Delhi - 110091.

Sir,

This has a reference to your outdoor diary no. 3486 dated 27/06/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 05/07/2024 in the presence of Mr. Vikas Tyagi (Manager), and observed that building comprised of Basement, Ground + 04 upper floors only.(Cinema Hall on 2nd, 3rd& 4thfloors)

Following shortcomings were observed during time of inspection:

- 1. Work for provision of fire check doors in is progress.
- 2. Pressurizationfan provided but not integrated with main fire panel.
- 3. Smoke Management System provided but not functional.
- 4. Fire Extinguisher not provided in projector rooms.
- 5. Public Address System provided but not functional.
- 6. More Exit signage to be provided in exit ways.
- 7. Fire blanket and First-aid box not provided in projector rooms.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

DIRECTURI CDELHI FIRE SERVICE

Copy to:-

- 1. The Ex. Engineer (Bldg.), MCD, 419, F.I.E. Udyog Sadan, Patparganj, Delhi 110092
- The Manager, Moon Shine Entertainment Limited (Chand Cinema) located at Trilok Puri, Delhi -110091.
- 3. The Deputy Health Officer, Shahdara South Zone, Shahdara, Delhi.
- 4. The Electrical Inspector, Govt. of NCT of Delhi, D- Block, 5 Sham Nath marg, Delhi.