

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110 001

No. F.6/DFS/MS/WZ/2024/ 393

Dated: 10/07/2024

To,

The Executive Engineer,
North West Building Division,
PWD, SU Block, Pitampura,
Delhi-110034.

Ref: 54(344)// का०/अभि/ उप०भ०/224-25/2024 dated 0706.2024

Sub: Regarding handing over to newly constructed boundary wall site, Name of work:- Construction of proposed Fire Station and staff quarters Delhi Fire Service at Plot No.1, Sector-41, Rohini, Delhi. (SH. Constructor of boundary wall in existing land).

Sir,

Please refer your letter referred above and received in this department in Outdoor Diary No. 2883 dated 12.06.2024 on the subject cited above. In this connection a team of officers including DCFO (WZ), ADO (Rohini) from DFS and J.E (Civil) from PWD visited the site and discussed that minimum facilities required to handover & takeover of the facility is required to be done as follows:

1. Submersible bore-well of 120 feet depth with 10 HP for filling of fire tenders is required to be provided inside the premises.
2. Water tank capacity at terrace of watch room is to be increased to 3000 liters and 25,000 liters U/G water storage tank for DJB water with 7.5 HP pump along with DJB water connection is required to be provided.
3. A porta cabin/tent 10 Firemen with cot and mattress facility till construction of temporary fire station is required to be provided.
4. Water cooler with RO facility, 2 air coolers is required to be provided.
5. A meter connection of 25 KW in favor of officer In charge, Fire station is required to be provided.
6. Rain water drain duly connected with city sewer line is required to be provided.
7. A DFS logo and Fireman portrait is required to be provided on wall as per drawing.
8. Bathroom fittings of watch room are not yet installed.

Therefore watch and ward may kindly be provided from PWD side till proper handover and take-over of the facility to avoid any theft or damage to installation.

Yours faithfully

(Atul Garg)
DIRECTOR

Copy To:-

The Executive Engineer (E), NWED, PWD (GNCTD). ISBT, Kashmiri Gate, Delhi-06

De
my