

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2024/ 394

Dated: 10/07/2024

To,

Dr. Alka Sachdev
Polyclinic for New Delhi Centre for Sight (Pvt) Ltd,
Sector - 9, Dwarka,
New Delhi - 110076

Subject: Renewal of Fire Safety Certificate iro Polyclinic for New Delhi Centre for Sight (Pvt) Ltd, Sector - 9, Dwarka, New Delhi.

Sir,

Please refer to your letter No. nil dated 12/06/2024 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officers concerned of this department on 05/07/2024 in presence of Ms. Vandana from fire safety point of view.

During course of inspection the following shortcomings are observed:

1. Pressurization System provided in staircase, lift shaft found nonfunctional.
2. Lift lobby found removed in basement.
3. Smoke Management system in basement found nonfunctional on auto mode and exhaust duct must be extended below the false ceiling in some area as indicated during the inspection.
4. Sprinkler must be extended below the false ceiling in some area as indicated during the visit.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)

Director
Delhi Fire Service

Copy to:-

1. The Dy. Director (L&I) Building, DDA, Vikas Sadan, INA, New Delhi.