



75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/2024/SZ/ 389

Dated: 09/07/2024

To

Sh. Anurag Arora (Administrator),  
Prime Ministers Museum and Library,  
Teen Murti Bhawan Complex,  
New Delhi-110011

**Sub: Regarding renewal of Fire Safety Certificate in r/o Prime Ministers Museum and Library at Teen Murti Bhawan Complex, New Delhi – 110011**

Sir,

This has reference to the application received through outdoor diary No. 2788 dated 11/06/2024, on the subject noted above. In this connection, the premise was re-inspected by the officers concerned of this department on 02/07/2024 in your presence, from fire safety point of view. During the inspection, the shortcomings observed are as below.

1. The electrical shaft at 1<sup>st</sup> floor (AHU) found unsealed.
2. Detector found non-functional and loose wiring, waste material in Cafeteria.
3. The exit signage found removed at some places.
4. Loose wiring, water leakage and waste material found in Freedom & Unity Hall, which is hazardous & risky from fire & life safety point of view.
5. Wall paneling need to be painted with fire retardant paint in Freedom & Unity Hall.
6. Detector & sprinkler to be extended in battery room (UPS) in Modi's Gallery.
7. Waste material stored under stairs and near ramp in Modi's Gallery to be shifted/removed.
8. Entry/exits in Souvenir shop are in same direction against opposite direction/side.
9. Waste material from new server room to be removed/shifted.

In view of the above, application for renewal of Fire Safety Certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE