



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F. 6. / DFS / MS / BP / 2024/ 383

Dated: 09/07/2024

To,

The Authorized Signatory,
Singhal Hospital,
C-40, Street No. 9,
Sadh Nagar, Palam Colony,
New Delhi -110045.

Sub:- Reply to your letter.

Sir,

Please refer your letter No. Nil dated Nil on the subject cited above. In this connection it is to inform you that the as-built plan, as submitted by you, has been examined and observed following shortcomings:

1. Width of access road is not provided.
2. Area chart is not provided.
3. Section / elevation drawings are not provided.
4. Door / window schedule is not provided.
5. Width of staircases is not marked on plan.
6. Width of main exits on ground is not marked on plan.
7. Width of corridor is not meeting the requirement of UBBL – 2016.
8. Entry to staircases and lift is not through Fire Check Doors.
9. Fire protection arrangements such as underground fire tank, overhead fire tank, hose reel, fire extinguishers etc. as stipulated in NBC-Part-4 are not marked on the plan.
10. Alternate exits / doors are not proposed in in patient ward / ICU.

Therefore, you are requested to rectify above shortcomings and re-submit the plans for further consideration in the matter.

Yours faithfully


3/7/24

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Ph.-011-23412025

Copy to:

The MS, Nursing Homes,
Directorate General of Health Services,
Govt. of NCT of Delhi, S-1, 3rd Floor,
School Block, Shakarpur,
Delhi – 110092.

- for information and n/a please.