




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



Dated: 16/07/2024

No: F.6/DFS/MS/School/2024/WZI 430

To,
The Principal,
Genius Kids Convent School,
Kh. No. 68/1, Shiv Mandir Street,
Bhorgarh, Narela, Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Genius Kids Convent School, Kh. No. 68/1,
Shiv Mandir Street, Bhorgarh, Narela, Delhi- 110040.

Sir,
This has reference to your email id dated 24.06.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 05.07.2024 to see the compliance of shortcomings communicated vide this department letter number F6/DFS/MS/2017/1710 dated 06/07/2017. Sh. Lalit Kumar (Manager) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Two upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. There is only one staircase of width 1.60 m provided against the requirement of two staircases of width 1.50 m each.
2. Only 04 fire extinguishers provided against the requirement of 07 extinguishers.
3. First aid hose reels found provided but not functional.
4. Terrace level pump of 450 lpm capacity found not provided.
5. Overhead tank of 10,000 ltrs capacity found not provided
6. Exit signage's not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

[Handwritten signature]

[Handwritten signature]

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.