

C-61

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2024/ 441

Dated: 16/07/2024

The Principal,
Kendariya Vidyalaya,
Tagore Garden, New Delhi – 110027.

Sub: - Renewal of Fire Safety Certificate in respect of Kendariya Vidyalaya located at Tagore Garden, New Delhi – 110027.

Sir,

Refer to your Email dated 07/06/2024, on the subject cited above. In this connection, it is to inform you that the premises was re- inspected by the officer concerned of this department on 02/07/2024 in the presence of Sh. Dr. Sanjay Kumar (Principal) to check the shortcomings already issued by this deptt. vide letter No.- F6/DFS/MS/School/WZ/2024/237 dated: 10/05/2024.

The Following Shortcomings Status is:-

S. no.	Shortcomings	Status
1.	First-Aid Hose Reels are provided but not functional.	Not Rectified
2.	Terrace level pump capacity of 2 X 450 lpm is provided but not functional.	Not Rectified
3.	Overhead water storage tank capacity of 2 x 10,000 ltrs is provided but found empty.	Not Rectified
4.	Exit Signage's are found removed at some places.	Rectified

In view of above shortcomings the application for renewal of fire safety certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director

Copy To: -

1. The Director, Directorate of Education, Old secretariat, Delhi – 110054.

11/7/2024