

C-103

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 417

Dated:- 12.07.2024

To,

The Manager
M/S Konark Guest House 30, Arakashan
Road, Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Konark Guest House at 30, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024052007856 dated 16/06/24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 02/07/24 in the presence of Sh. Brij Mohan and following shortcomings were observed: -

1. CO type detectors found nonfunctional.
2. PA system found non functional.
3. Exhaust found nonfunctional.
4. Standby Power Supply is not provided.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police(lic), 1st floor, Defence Colony Police Station, New Delhi