

120

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2024/ 428

Dated: 16/07 /2024

To

The Principal,  
(R.S) Lakshmi Narain Saraswati Girls Sr. Secondary School,  
Katra Neel, Chandni Chowk, Delhi - 110006.

**Sub:-** Regarding issuance of Fire Safety Certificate in r/o (R.S) Lakshmi Narain Saraswati Girls Senior Secondary School, Katra Neel, Chandni Chowk, Delhi -06.

Sir,

This has reference to letter no. RSLN/24/1966 dated 05.07.2024 received in this department on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 11.07.2024 in the presence of Mrs. Sonia Gogia (In-charge) and it was observed that the school building is comprised of ground + mezzanine + 02 upper floors and have complied the shortcomings issued vide letter no. F6/DFS/MS/2019/6975 dated 20.11.2019 except following which still exists:-

1. The school is not accessible to fire engines as approach road width is less than 06 meters.
2. First aid hose reels not provided at each floors.
3. Fire pump having capacity 450 LPM out put with 40 m head is not provided.
4. Over head water storage tank of 10,000 liters capacity is required exclusively for firefighting.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,

  
(Atul Garg)

Director  
Delhi Fire Service  
Tel: 011-23414000

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi