




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2024/WZI 435

Dated: 16/07/2024

To,

The Principal,
M.C. Primary School,
B-2 (1st), J.J. Colony, Bawana,
Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M.C. Primary School, B-2 (1st), J.J. Colony, Bawana, Delhi- 110039.

Sir,

This has reference to your email id dated 29.06.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 05.07.2024 to see the to see the compliance of the requisite fire safety measures. Smt. Neelam (Principal) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Three upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. There is only 01 continuous staircase up to the terrace against the required 02 continuous staircases up to the terrace.
2. First aid hose reels found not provided.
3. Terrace level pump of 450 lpm capacity found not provided. The pump should be auto mode.
4. Overhead tank of 10,000 ltrs capacity found not provided
5. Exit signage's not provided.
6. Electrical meter and panel installed under the staircase has to be removed to a safer place.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.