

C-38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 434

Dated: 16/07/2024

To,

The Principal,
M.C Primary Co-Ed School (Id- 1556016),
C-5, Janakpuri, New Delhi-110058.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o M.C. Primary Co-Ed School (Id- 1556016), C-5, Janakpuri, New Delhi-110058.

Sir,

Please refer to your letter No. Nil, dated 06.06.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 09.07.2024 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Mrs. Leena Joon (Manager) was present and it was observed that the building is comprised of ground floor plus two upper floors and have following shortcomings: -

1. Inspection ladder approaching to terrace level found removed.
2. Hose reel found provided but not functional.
3. Terrace fire pump provided but found not functional.
4. Overhead water storage tank of 2,000 ltrs. found provided against requirement capacity of 10,000 ltrs.
5. Exit signage's are provided but not sufficient.
6. All exit ways should be opened without any obstruction at school time.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.