



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



C-36

No. F6/DFS/MS/2024/School/ 439

Dated: 16/07/2024

To

The Principal
M.C. Primary School
at Samaypur Old-II, Delhi-110042.

Sub: -Regarding issuance of fire safety certificate in r/o M.C. Primary School (School ID No-1253161) located at Samaypur Old-II, Delhi-110042.

Sir,

Please refer to your letter No. Nil dated 10.06.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 06.07.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floors only. At the time of inspection Smt. Kavita Rani (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Fire extinguisher is provided but not functional at the time of inspection.
2. Hose reel hose is provided but not functional & badly damaged/leakage condition.
3. Terrace level fire pump capacity of 450lpm is provided but not functional & damaged condition.
4. Terrace level fire water tank capacity of 10,000ltr is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
5. Exit and floor signage's is not provided at strategic locations in the building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Anul Garg)

Director

Ph:-011-23414000

gcp

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.