

35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 443

Dated: 16/07/2024

To,
The Principal,
M.C.D. Co-ed, Primary School,
Khazan Basti, New Delhi-110064.

Sub: - Regarding renewal of FSC from fire safety point of view in r/o M.C.D. Co-ed, Primary School at Khazan Basti, New Delhi-110064.

Sir,
Please refer to your letter No. Nil dated 04.06.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 03.07.2024 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Alka Verma (In-charge) was present and it was observed that the building is comprised of ground floor plus two upper floors and have following shortcomings: -

1. Hose reel found provided but not functional.
2. Terrace fire pump 450 LPM found provided but not functional.
3. Overhead water storage tank of 6,000 ltrs found empty and another tank of 4,000 ltrs found broken.
4. Exit signage's are provided but not sufficient.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Ajul Garg)
Director
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.