

C-40

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 438

Dated: 16/07/2024

To,

The Manager,
P.M. School, B-10, Madhu Vihar,
Som Bazar road, Uttam Nagar, New Delhi-110059.

Sub: - Regarding renewal of FSC from fire safety point of view in r/o P.M. School locate at B-10, Madhu Vihar, Som Bazar Road, Uttam Nagar, New Delhi-110059.

Sir,

Please refer to your letter No. Nil, dated Nil, received in this office outdoor dairy No. 3356 dated 24.06.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 08.07.2024 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Priyanka (Teacher) was present and it was observed that the building is comprised of ground floor plus two upper floors and have following shortcomings: -

1. Second staircase/fire escape route found blocked from ground floor to second floor.
2. Hose reel found provided but not functional.
3. Terrace fire pump 450 LPM found provided but not functional in auto mode.
4. Overhead water storage tank of 6,000 ltrs. found provided against requirement capacity of 10,000 ltrs.
5. Exit signage's are provided but not sufficient.

In view of above, renewal of FSC cannot be considered at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.