

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/GH/2024/SZ/419

Dated 12/07/2024

To

The Joint Commissioner of Police,
Lic / Branch, 1st floor, Police Station
Defence Colony, New Delhi 110049.

Sub: - Regarding issuance of fire safety certificate in r/o M/s SHALIMARR Hotel at Plot No A-160, Road No 4, Mahipalpur New Delhi 110037.

Sir,

This has reference to with **MHA Portal ID 20240562409889 dated 27/06/2024** on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10/07/2024 in the presence of Mr. Hemant Kumar (Manager) to verify the fire safety arrangements installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 Overhead tank capacity 5,000 ltrs provided against the required capacity 10,000 ltrs.
- 2 Kitchen running in basement is not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE