



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/07/24
आपत्ती का
अमृत महोत्सव

Dated: 16/07/2024

No. F6/DFS/MS/School/NDZ/2024/ 43)

To,

Mrs. Parul Chaudhary (Principal),
Sun Shine Modern Public School,
F - Block, 40ft. Road, Ganga Vihar,
Delhi - 110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o Sun Shine Modern Public School located at F - Block, 40ft. Road, Ganga Vihar, Delhi - 110094.

Sir,

This has a reference to your outdoor dairy no. 3617 dated 01/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 08/07/2024 in the presence of Mrs. Parul Chaudhary (Principal), and observed that building comprised of ground plus two upper floors only.

Following shortcomings were observed during time of inspection:

1. Two staircases of width 1.64 meters and 0.74 meter are provided against the requirement of two staircases of width 1.50 meters each.
2. The size of class room doors is 0.80 meter against the requirement of 1.20 meter each.
3. Fire Extinguisher not provided.
4. First-Aid-Hose Reel not provided.
5. Fire pump of 450 LPM not provided.
6. Overhead tank of capacity 10,000 liters not provided.
7. Exit signage's not provided in strategic locations in the school building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi -110054.