



75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/ 427

Dated: 16/07/2024

To

The Principal,  
Swiss Cottage School,  
Village Salahpur, New Delhi-110061.

**Sub: Regarding renewal of Fire Safety Certificate in r/o Swiss Cottage School, Village Salahpur, New Delhi-110061.**

Sir,

This has reference to the application received through outdoor diary No. 3559 dated 28/06/2024, on the subject noted above. In this connection, the premise was re-inspected by the officers concerned of this department on 05/07/2024 in your presence, from fire safety point of view. During the inspection, the shortcomings observed are as below.

1. Hose reel found non-functional.
2. Terrace pump and overhead tank could not be check as the inspection ladder provided is vertical at 90-degree angle, thus not accessible.
3. The exit signage found removed at some places.
4. Two blocks each comprised of ground plus one upper floor is used for school activities (day care/play school) despite the condition regarding not to use these blocks for school activities without obtaining FSC from this department.

In view of the above, application for renewal of Fire Safety Certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054