



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/10/24
आजादी का
अमृत महोत्सव

27.
228

No.F6/DFS/MS/School/SZ/2024/ 456

Dated: 19/07/2024

To

The Principal,
M/s Cambridge School,
Srinivas Puri, Ring Road, New Delhi-65.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Cambridge School located at Srinivas Puri, Ring Road, New Delhi-65.

Sir,

With reference to letter bearing outdoor diary no. 3203 dated 21.06.2024 on the subject cited above, it is informed that the said building was inspected by the officer concerned of this department on 04.07.2024 in the presence of Mrs. Madhavi Goswami (Principal) and it was observed that school building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. Hose reel found not functional
2. Fire pump found not functional.
3. Overhead tank capacity 5,000 liters is provided against the requirement of 10,000 liters.
4. Exit sinages found removed.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

o/c
12/7

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.