

E-201

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/School/2024 458

Dated: 19/07/2024

To,

The Principal,
Govt. Girls Sr. Sec School No.1,
Khyala, New Delhi: - 110018.

Sub: - Inspection report in respect of Govt. Girls Sr. Sec School No.1, Located at Khyala, New Delhi: - 110018.

Sir,

With reference to your Email dated 07/06/2024 on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 05/07/2024 in the presence of Smt. Rashmeet Kaur (Principal) to see the functioning of the fire safety equipments provided in the building.

During inspection, it has been observed that the School comprised of two blocks, Ground + 03 upper floors in each block + one MP Hall. Fire safety arrangements such as, Fire Extinguishers, First-Aid Hose reels, Pumping arrangements, Terrace pump, etc. are provided in the building.

However, following shortcomings were observed: -

1. First Aid Hose reels are provided but not functional.
2. Terrace fire pump capacity of 900 lpm is provided but not functional.
3. Overhead water storage tank capacity of 10,000ltr is found empty.
4. Exit signage's found removed at some palaces.

In view of above shortcomings, the application for renewal Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi - 110054.

o/c

16/7/2024