



No. F6/DFS/MS/Industrial/NDZ/2024/ 414

Dated 23/07/2024

To,

Mrs. Veena Kumari (Owner),  
Plot no. 373, F.I.E,  
Patparganj Industrial Area,  
Delhi - 110092.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Plot no. 373, F.I.E located at Patparganj Industrial Area, Delhi - 110094.**

Sir,

This has a reference to your outdoor Diary No. 3695 dated 02.07.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 06.07.2024 in the presence of Mrs. Veena Kumari (Owner) and observed that building comprised of basement, ground plus two upper floors only.

**Following shortcomings were observed during time of inspection:**

1. Two staircase of width 1.25 meter & 0.75 meter are provided against requirements of 1.50 meter each.
2. Fire check door not provided.
3. Exhaust fan not provided in basement.
4. Exhaust fan not provided in upper floors.
5. First-aid-Hose Reels provided but not functional.
6. Automatic Sprinkler System provided but not functional.
7. Fire pump of 900 LPM provided but not functional.
8. Overhead tank of 5,000 liters capacity is provided against the requirement of 10,000 liters.
9. Exit & floors Signage's not provided in strategic location in the building

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(APUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, 419 Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.