



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/ 1634

Dated: 23/07/2024

To

Dr. Gajanan L Katade,
Dy. Superintending Archeologist,
Govt. of India, Ministry of Culture,
Dharohar Bhawan, 24, Tilak Marg,
New Delhi.

Sub: 46th Session of the World Heritage Committee to be held during July, 21-31, 2024 at New Delhi (Dilli Haat INA visit scheduled on 27th – 28th July 2024).

Sir,

This has reference to your letter No. T-26017/49/WH dated 06/07/2024 on the subject cited above. In this connection, it is to inform you that site at Dilli Haat (INA) has been visited by the officers concerned of this department on 19/07/2024 from fire safety point of view in the presence of Mr. Rajan Kumar Swain (AE-Elect) and observed that there are various facilities such as Food Court, Craft Section, Shops, Amphitheatre, Kids Zone, Abdul Kalam Memorial, Parking etc.

Further, during the event/program, fire prevention and fire safety measures shall include unobstructed access to site, distance from medium and high voltage electric wires and hazardous installations, means of exits, material of construction, water storage for firefighting, electrical wiring, availability of trained firefighting staff in accordance with IS 8758 and National Building Code of India may be ensured. The section 26 (2) of the Act 2007 read with Rule 30 provides that the erector of the pandal shall display a declaration in the prescribed format as per Form "D" at a prominent place in the pandal, in case pandal is erected.

The following conditions shall always be adhered to: -

1. Trained fire personnel shall always be available at the site of function.
2. All exits shall always be clear and there should be no obstruction in the exits/entrance gate.
3. No special effects creating fire / crackers should be used at site.
4. LPG /Open flame should not be used for preparation of foods in the premises.
5. There should be no open electric cable joints

Any loss of life and property due to non-compliance of the above conditions, the management/organization shall be responsible solely.

Yours faithfully,

(ATUL GARG)
DIRECTOR
T. No. 23414000

Copy to: -

1. The Executive Engineer, DTTDC Limited, New Delhi, Srinivaspuri, Lajpat Nagar, Near Cambridge School, Ring Road, New Delhi-110065