

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/Hospital/SZ/2024/ 420

Dated: 25/07/2024

To

Executive Engineer (E),  
PWD Heath Maintenance Electrical Division,  
(South West) PWD, Delhi Armed Police Line,  
Vikasuri, New Delhi- 110018.

Sub:-Regarding issuance of Fire Safety Certificate in respect of renovated Block-A, Newly Constructed New Block including Existing Functional Block B & C at Dada Dev Hospital, Nasirpur, New Delhi.

Sir,

Please refer to your letter No.23(19)1/HSW1/P.W.D.H.M.E.D.S.W./2024-25/1202-H, dated 18.07.2024, on the subject cited above. In this connection it is to inform you that the above said Hospital building was inspected by the officers concerned of this department from safety point of view on 11.06.2024 in presence of Executive Engineer (Elect.) & Executive Engineer (Civil), and found that the construction/renovation works is under progress. This department has already issued a letter in this matter vide letter No. F.6/DFS/MS/Hospital/SZ/2024/1131 dated 29.05.2024. during the course of inspection following shortcomings were observed: -

1. Fire Check Doors of two hours fire rating not provided in the lift lobby and other areas which comes between newly constructed area and running hospital at all floor levels. Segregation of newly constructed building and old block is required.
2. Ventilation system of upper floors in new block is not functional.
3. Pressurization system is not provided in lift lobby and lift shaft.
4. Positioning of staircases in new block create dead end which only be removed after complete construction work.
5. Sprinklers and smoke detectors need to be installed in left out area.

However, fire-fighting arrangements such as underground water storage tank and pumps installed in old building found functional. In view of above, you are requested to apply after completion of the construction/renovation work and rectify the above-mentioned shortcomings for further necessary action in the matter.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. Medical Superintendent, Dada Dev Child Care & Maternity Hospital, Nasirpur, Dabri, New Delhi.