

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/Hospital/2024/SZ/ 419

Dated: 24/07/2024

To,

The Authorized Signatory,  
M/s Commander Hospital, Plot No. 55, 56 & 57,  
Shiv Vihar West, Vikas Nagar, New Delhi-110059.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. M/s Commander Hospital, situated at Plot No. 55, 56 & 57, Shiv Vihar West, Vikas Nagar, New Delhi-110059.

Sir,

This has reference to your Letter No. Nil dated 11.06.2024, on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the hospital on 09.07.2024 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Mohit Kaushik was present and it was observed that the hospital building is comprised of lower ground, upper ground plus three upper floors and have following shortcomings.

1. 02 staircase having width of 1.80 m each found provided against requirement of 02 staircase having width of 2.0 & 1.50 m from lower ground floor to terrace level.
2. Fire check doors found not provided and lift lobby should be provided.
3. Second staircase is not approachable through corridor.
4. Door width of 1.80 m found provided against required door width of 2.0 m.
5. Ventilation system found not provided at some places.
6. Hose reels/hydrant found provided but not functional.
7. Sprinkler system should be extended in left out area.
8. Underground fire pump found provided of 900 LPM against requirement of 1620 LPM main pump, 1620 LPM standby diesel pump and 180 LPM jockey pump.
9. Detail measurement of the underground water storage tank should be provided.
10. Exit Signes found not provided.

Keeping in view of above, issuance of Fire Safety Certificate can-not be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. MS, Nursing Homes, DGHS, Govt of NCT of Delhi, S-1, 3<sup>rd</sup> Floor, School Block, Shakarpur, Delhi-110092.