

C 197

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/Hotel/SZ/2024/ 26

Dated 15/07/2024

To,  
The Joint C.P. (LIC.),  
1<sup>st</sup> floor, Police Station,  
Defense Colony, New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o M/s. Hotel Signature Grand located at 1-A, Sub-District Centre, Hari Nagar, New Delhi- 110064.

Sir,

Please refer to online application ID 2024061309349 dated 18.06.2024, on the subject cited above. In this connection, it is to inform you that the above said Hotel building comprised of two tier basement, ground plus six upper floors with service floor. The above said premises was inspected by the officer concerned of this department from safety point of view on dated 11.07.2024 in presence of Sh. Popli.

During the course of inspection, the following shortcomings have been observed: -

- 1 Internal road found blocked by permanent office structure.
- 2 Exit ways found blocked at some places.
- 3 Fire Pumps found provided but not functional in auto mode.
- 4 Exit singes found removed at some places.

Keeping in view of above, renewal of fire safety certificate cannot be considered at this stage. Hotel management may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service  
07/06/24

Copy to-

1. The Owner/Occupier, M/s. Hotel Signature Grand located at 1-A, Sub-District Centre, Hari Nagar, New Delhi- 110064.