

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
Connaught Place: New Delhi-110001

No. F.6/DFS/MS/2024/BP/406

Dated: 18/07/2024

To,

The Executive Engineer (Bldg.) HQ
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road
New Delhi 110002.

Subject: Regarding clearance of building plans from fire safety point of view in r/o Plot No. 65/2, Block-C, Okhla Industrial Area Phase-II, New Delhi.

Sir,

Please refer your ID No. 10118991 dated 11.07.2024 on the above cited subject. In this connection, this is to inform you that the matter was examined and observed that there is an online proposal for construction of industrial building at Plot No. 65/2, Block-C, Okhla Industrial Area Phase-II, New Delhi. The proposed building is comprised of basement + stilt + ground + 03 upper floors having height 14.885 meter. Following shortcomings are observed:-

1. Staircases are not remotely located as per clause 7.8 of UBBL 2016 and also are not discharging as per clause 7.11 of UBBL 2016.

Accordingly, the case is rejected.

Yours faithfully

(Atul Garg)
Director
011 23414000

[Handwritten signature]