

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2024/SZ/ 107

Dated 18/07/2024

To

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 11049

Sub: -Regarding issuance of fire safety certificate in r/o **M/s Village Good Court Pvt Ltd VFC** located at Shop No G26A, G-26B, CGF Plot No at A- Pocket-V, Sector-B, Ground floor, Vasant Square Mall, Vasant Kunj, New Delhi-110070.

Sir,

This has reference with **MHA Portal ID 2024062109722 dated 25/06/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10.07.2024 in the presence of Mr. Deepak Kumar (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 The minimum clear head way of exit door shall not be less than of 2.20m in height as per UBBL 2016.
- 2 There is a LPG bank/ storage adjoining to the exit pathway of kitchen / alternative exit which need to be removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE