

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE  
Connaught Place: New Delhi-110001

No. F.6/DFS/MS/2024/BP/ 444

Dated: 18/07/2024

To,

The Executive Engineer (Bldg.) HQ  
Municipal Corporation of Delhi,  
9<sup>th</sup> floor, Civic Centre, Minto Road  
New Delhi 110002.

Subject: Regarding clearance of building plans from fire safety point of view in r/o addition/ alteration in existing educational building of Ramakrishna Sarada Mission, located at C-8A, Hauz Khas, New Delhi – 16

Sir,

Please refer your ID No. 10118961 dated 11.07.2024 on the above cited subject. In this connection, this is to inform you that the matter was examined and observed that there is an online proposal for addition/ alteration in existing educational building of Ramakrishna Sarada Mission, located at C-8A, Hauz Khas, New Delhi-16. The proposed building is comprised of Ground + 02 upper floors having height 13.27 meter. Following shortcomings are observed:-

1. Exits are not planned in various areas such as activity area, lecture hall etc.
2. Exits are not arranged as per clause 7.5.10 of UBBL 2016.
3. Width of exit door/ corridor of assembly area is not as per clause 7.23.2 (e) of UBBL 2016.
4. Proposed lift is not planned as per clause No. 4.4.2.4.3.2 (h)(6) of NBC Part 4.

Accordingly, the case is rejected.

Yours faithfully

(Anil Garg)  
Director

011 23414000

908 @ 3