



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 464

Dated: 25-07-2024

To

The Principal,
Hemnani Public School,
Baba Nebhraj School Marg, Opp. G – Block,
Lajpat Nagar-I, New Delhi-24.

Sub: Regarding renewal of Fire Safety Certificate in respect of **Hemnani Public School** located at **Baba Nebhraj School Marg, Opp. G – Block, Lajpat Nagar-I, New Delhi-24.**

Sir,

This has reference to letter bearing outdoor diary no. 1584 dated 10.05.2024 on the subject cited above. In this context it is informed that the said building was inspected by the officer concerned of this department on 16.07.2024 in the presence of Mrs. Geeta Balani (Principal) and it was observed that school building is comprised of Ground + 02 upper floors. During the inspection following shortcoming were observed:-

1. Hose reel found non functional
2. Down comer system found non functional.
3. Fire pump found non functional.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.