

C-105

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 439

Dated: 23/07/2024

To

The Joint Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in respect of M/s Hotel Good Times Located at 8/7,
WEA Karol Bagh New Delhi.

Sir,

Please refer to online application No. 2024020601280, dated 02/04/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 18/07/2024 in the presence of Sh. Himansu Bansal (Employee) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Smoke management system in basement & Upper Floor found Non functional/ inadequate/ removed not interlinked with MOEFA.
2. Only one fire extinguishers of ABC type 4Kg capacity is found provided against required two fire Extinguishers at each floor.
3. CO detectors found not provided
4. PA system found nonfunctional
5. Pumps at terrace level found nonfunctional on auto mode.
6. Exit Signage found Removed at same places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.


(Atul Garg)
Director
Delhi Fire Service

Copy to: - The Manager, M/s Hotel Good Times Located at 8/7, WEA Karol Bagh New Delhi.