

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/GH/WZ/2024/ 429

Dated: - 19/07/2024

To,

Sh. Azad Yadav,
M/s. Hotel Shyam Kunj,
59, G.F., F.F, S.F. & T.F,
Samrat Enclave, Pitampura,
Delhi- 110034.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Hotel Shyam Kunj located at 59, G.F F.F., S.F., T.F. Samrat Enclave, Pitampura, Delhi- 110034.

Sir,

Please refer to MHA application ID 2024062609955 dated 27.06.2024 on the subject cited above. In this connection it is to inform you that the above said guest house building was re-inspected by the officer concerned of this department on 11.07.2024 in presence of Sh. Sandeep Yadav to check the fire safety measures provided in the building.

During the course of inspection, it has been observed that fire safety arrangements such as fire extinguishers, hose reels, detectors found provided, However the following shortcomings have been observed: -

- 1 Basement floor is not compartmentalized/ segregated providing fire check door.
- 2 The width of corridor found less than 1.8 m.
- 3 Staircase and lift are not segregated. Lift in between staircase is not allowed as per UBBL- 2016.
- 4 Smoke management system in basement found not provided.
- 5 Sprinkler found not provided in left out area.
- 6 Terrace pump not found in auto mode.
- 7 Inspection ladder found not provided.
- 8 Overhead water tank found empty.
- 9 Exit signages are not provided.
- 10 Fire pump and fire pump panel has to be removed from staircase.
- 11 Rooms on fourth floor has to be removed/ demolished.

In View of the above, the application for issuance of Fire Safety Certificate is not considered at this stage and rejected. You are requested to re-apply on MHA portal as and when site is ready for inspection.

Yours faithfully,


(Atul Darg)
Director

Ph: 011-23414000

Copy to: -

1. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station, Defence Colony, New Delhi- 110049.
2. MHA Portal ID No. 2024062609955.