

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/ 422
To

Dated: 29/07/2024

Mr. Kusal Bazar Owners &
Occupants Association (Regd)
407, 32-33 Nehru Place,
New Delhi 110019.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Kusal Bazar located at 32-33 Nehru Place, New Delhi- 110019.

Sir,

This has reference with your letter received through Outdoor diary no 3822 dated 05/07/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 11/07/2024 in the presence of Mr. Sushil and observed to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The Fire Check door self closing device found removed at some place.
2. Smoke ventilation system provided but found nonfunctional.
3. First aid hose reel provided but found nonfunctional.
4. Automatic detection system found removed.
5. MOEFA Not working.
6. Internal hydrant provided but found nonfunctional.
7. Fire fighting pumps provided but found nonfunctional.
8. Overhead tank capacity 35,000 ltrs found removed.
9. Exit signage's found removed.
10. Electrical installation / meter found installed in the escape routes near staircases, which is not acceptable.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg) MCD, Jal Vihar, Lajpat Nagar, New Delhi 110024