

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/293

Dated 19/07/2024

To

The Joint Commissioner of Police  
(Lic. /Branch), 1<sup>st</sup> Floor, P.S. Defence Colony,  
New Delhi-110049.

Sub: -Regarding issuance of fire safety certificate in r/o M/s Mqdc India Real Estate  
Pvt Ltd. Shop No SG1, DT Greater Kailash II, New Delhi- 110048.

Sir,

This has reference to your **MHA Portal ID 2024062209783** dated **22/06/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.07.2024 in the presence of Mr. Rahul Kumar to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. Fire door for segregation / Compartmentation of kitchen & seating area found removed.
2. First aid hose reel provided but non-functional in the restaurant area.
3. Integrated Sprinkler not provided.
4. Integrated hydrant not provided.
5. Exit signage found removed at some places.
6. Inflammable material (Plastic green leafs decorative material) used in wall paneling ceiling level, which is not acceptable.

The same observations has already been issued and communicated earlier by this department vide letter of even no 170 dated 08/05/2024.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

el m w