

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/MS/DFS/Hospital/2024/SZ/423

Dated 29/07/2024

To

The Executive Engineer (E)
PWD Health Maintenance Electrical Division,
South West Govt. of Delhi, Armed Police line,
Vikas Puri, New Delhi 110018.

Sub: Regarding issuance of Fire Safety Certificate in r/o Pt. Madan Mohan Malviya Hospital, Malviya Nagar, New Delhi-110017.

Sir,

This has reference with letter no 23(19)2Swa.D.P.2/L.N.V.Swa.Anu,Va.M.S.P/2023-24/907-7 dated 05/07/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23.07.2024 in the presence of Mr. Mr. Jitender Prashad (JE) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 First aid hose reel provided but found nonfunctional.
- 2 Automatic detection system found partially working.
- 3 Automatic sprinkler system provided but found nonfunctional.
- 4 Internal hydrant and yard hydrant provided but found nonfunctional.
- 5 Fire fighting pumps are not on auto mode due to leakage in the main fire water piping network.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

[Handwritten signature]