



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/55  
आपादीय  
अग्नि महोत्सव

No. F6/DFS/MS/School/NDZ/2024/ 470

Dated: 26/07/2024

To,

The Principal,  
School of Excellence,  
Khichripur Village Delhi - 110091.

**Sub: - Regarding grant of Fire Safety Certificate in r/o School of Excellence located at Khichripur Village Delhi - 110091.**

Sir,

This has a reference to your email dated 04/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 10/07/2024 in the presence of Mr. Rajesh (Principal) & Mr. Ranjan Singh (Estate Manager) and observed that school building is comprised of ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel provided but not functional.
2. Fire pump of 450 LPM provided but not functional.
3. Exit Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

O/C DELHI FIRE SERVICE  
W

Copy to:-

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi.
2. The Principal, School of Excellence located at Khichripur Village Delhi-110091.